

## Partially treated sewage surfacing at Marley Run which resembles Shoppes @ Apple Greene treatment plant



State permit condition prohibiting surfacing of sewage.

Permit No. 07-DP-3400

Page No 5

3. Operation of the subsurface drip irrigation system shall not cause surface runoff and/or ponding. The Permittee shall install or provide a storage facility designed to hold treated wastewater during periods when irrigation cannot take place. The storage facility shall be capable of containing wastewater generated during no less than 60 days of normal operation of the wastewater facility. The storage facility shall be sealed or constructed to prevent the direct seepage of stored waters into ground waters beneath the site.